

**TOWNSHIP OF HILLSBOROUGH
MUNICIPAL UTILITIES AUTHORITY**

SCHEDULE 1

Type of Establishment	Measurement Unit	Gallons Per Day
Single family residential dwelling	dwelling	300
Multiple family residential dwellings including townhouses, condo- miniums and apartments.		
1 bedroom unit	dwelling	180
2 bedroom unit	dwelling	255
3 bedroom unit	dwelling	300
Senior (age restricted) housing:		
1 bedroom unit	dwelling	110
2 bedroom unit	dwelling	170
3 bedroom unit	dwelling	225
Assisted living facilities *	bed	100
Health care facilities: *		
Hospitals	bed	175
Nursing or rehabilitation facilities	bed	125
Hotels, Motels*	bedroom	75
*The gallons per day for these facilities apply to the beds or bedrooms only. Additional flows will be calculated for kitchens, restaurants, bars, laundries, etc. in accordance with Section I.(D).		
Restaurants:		
full service	seat	35
bar/cocktail lounges	seat	20
fast food	seat	15
24 hour service	seat	50
curb service/drive-in	car space	50
Catering/banquet hall	person	20
Schools (includes staff):		
no shower or cafeteria	student	10
with cafeteria	student	15
with cafeteria and showers	student	20
with cafeteria, showers and laboratory	student	25
boarding	student	75

SCHEDULE 1 (CONT'D.)

Type of Establishment	Measurement Unit	Gallons Per Day
Churches (worship area only)	seat	3
Clubs:		
residential	member	75
non-residential	member	35
tennis, racquetball	per court per hour	80
Camps:		
children's residential	bed	50
day camps (no meals)	person	15
parked mobile trailer site	site	200
campground/mobile recreational vehicle/tent	site	100
Firehouses, rescue squad buildings	seat	3
Theaters	seat	3
Dinner theaters	seat	20
Bowling alleys	alley	200
Sports Stadiums	seat	3
Laundromats	machine	300
Automobile service stations	filling position	125
with service bays	bay	50
with mini-market	sq. ft.	.100
Stores and shopping centers	sq. ft.	.100
Office Buildings	sq. ft.	.100
Factories, warehouses, industry (does not include process wastewater)	employee	25
Factories, warehouses, industry with showers (does not include process wastewater)	employee	40